

Außenstelle Erwitte • Auf den Thränen 2 • 59597 Erwitte • Telefon (02943) 897-0 • Telefax (02943) 897 33 • E-Mail: erwitte@mpanrw.de

# Report of the classification of the reaction to fire performance

No. 230011289-3

issued 30.01.2018

English version

## **Sponsor**

ORAFOL Europe GmbH Orafolstraße 2

16515 Oranienburg

#### Order

Classification of the reaction to fire performance according to DIN EN 13501-1:2010-01

Date of order: 06.03.2014 and 30.11.2017

Identification number of the notified testing institute: 0432

# Name of the classified product:

White respectively colourless digital print foils "ORAJET 3551G" printed with solvent ink respectively latex ink and laminated with "ORAGUARD 215 G"

This report gives the classification of the above-mentioned building product in accordance to the procedure given in DIN EN 13501-1.

Publishing and copying of classification reports without permission of the MPA NRW is only allowed without any changes of the content and the form of the reports.

The shortened reproduction of classification reports needs the permission of the MPA NRW.

This classification report consists of 3 pages.



## 1 Description of the building product

White respectively colourless, glossy polymer PVC foils, one-sided coated with a grey respectively colourless adhesive on basis of a polyacrylate; the foils will be printed with solvent based inks respectively latex inks by digital printing on the visible side. The printed foils will be finally affixed with a transparent, glossy protective laminate foil made of polymer PVC, which is one-sided coated with an adhesive on basis of a polyacrylate.

Thickness of the foils "ORAJET 3551G": 0.096 mm ± 20 %

Thickness of the protective laminate foil "ORAGUARD 215 G": 0.099 mm ± 20 %

Thickness of the foil compound: 0.195 mm ± 20 %

Mass per unit area of the foil "ORAJET 3551G arktikweiß (101)": app. 128 g/m² Mass per unit area of the foil "ORAJET 3551G transparent": app. 112 g/m²

Mass per unit area of the protective laminate foil "ORAGUARD 215 G": app. 118 g/m²

# 2. Test reports and test results supporting the classification

### 2.1 Test reports

Name of the test laboratory	Sponsor	No. of the test report	Test procedure
MPA NRW	ORAFOL Europe GmbH	230011289-1 of 30.01.18 230011289-2 of 30.01.18	

# 2.2 Test results

The following test results are the basis of the classification

	Parameter	Number of tests per-formed	Test results	
Test method			Average values of continously parameter	Requirements of diskrete parameter
DIN EN ISO 11925-2 30 s flaming time	Flamespread ≤150 mm Burning droplets/particles	48		yes no
	FIGRA <sub>0.2</sub> in W/s		240	
	FIGRA <sub>0.4</sub> in W/s		215	
	THR <sub>600s</sub> in MJ		2,1	
DIN EN 13823	LFS <sub>edge</sub>	8		< edge
J.14 Z.14 10020	SMOGRA in m <sup>2</sup> /s <sup>2</sup>	·	22	
	TSP <sub>600s</sub> in m <sup>2</sup>		46	
	Duration of burning droplets/particles in s		0	



## 3. Classification and direct field of application

#### 3.1 Reference

This classification was carried out in accordance to the clauses 11 and 14 of the standard DIN EN 13501-1:2010-01.

### 3.2 Classification

The tested building product in relation to its reaction to fire behaviour is classified as:

The additional classification in relation to smoke production is:

s2

The additional classification in relation to flaming droplets/particles is:

d0

The classification of the reaction to fire performance is therefore:

Fire behaviour	Smoke devel- opment	Flaming droplets
С	s2	d0

i. e. **C - s2,d0** 

## 3.3 Field of application of the product

The classification is valid solely for the product described in clause 1 for the application on substrates made of gypsum boards as well as on substrates of the Euroclass A1 or A2-s1, d0 with a density of  $\geq$  525 kg/m³ and a thickness of  $\geq$  12 mm which are used in practice.

#### 4. Restrictions

This classification report does not represent type approval or certification of the product.

#### 5. Remark

This classification report written in English language is issued additionally to the report written in German language with the same report number. In case of doubt the German version is valid solely.

Erwitte, 30.01.2018

On behalf

Dipl.-Ing. Schreiner

Assistant Head of notified testing body

Date of issue of this English version: 30.01.2018